

**Response of
Wisconsin Power and Light Company
to
The Public Service Commission of Wisconsin
Data Request No. 3.09**

Docket Number: 05-CE-137
Date of Request: March 11, 2009
Information Requested By: Ken Detmer
Date Responded: March 30, 2009
Author: Jeff Knier
Author's Title: Project Director CACP
Author's Telephone No.: (608) 458-4866
Witness: (If other than Author)

Data Request No. 3.09:

Follow-up to Question 1.22: Should SO₂ emissions be reduced further, is there still sufficient room to install a FGD unit on Edgewater 5 if both a new baghouse and SCR are installed? This question is being asked since Edgewater 5 will likely be the largest remaining source of uncontrolled emissions of SO₂ after 2015.

Response:

Yes, sufficient space for the addition of a future scrubber and baghouse is available on the current site.